

INSPECTION CERTIFICATE

Registration No.: 005/15

Manufacturer: **KE-ARM, s.r.o.**
Pekařská 1639/79A
CZ – 747 05 Opava

ID: **13642511**

Product: **ball valve with adjustment for actuator**

Type designation: **KM 913X.X**
with rubber sealing

Type: **DN 10–65, PN 16–250**
DN 80–100, PN 16–160
with application to –40 °C
NPS ¾"–2 ½", Class 150–1500
NPS 3"–4", Class 150–900
with application to –40 °C

Technical standard and regulations: **ČSN EN 61508-1, ed.2; ČSN EN 61508-2, ed.2**

Inspection report No: **5215114/01**

Inspection Body TÜV NORD Czech, s.r.o. as an independent organization (third party) according to ČSN EN 61508-4, Article 3.8.12 confirms that the ball valve with adjustment for actuator of above mentioned types meet the requirements of the systems with functional safety SIL2 (for single device) according to ČSN EN 61508, type B.



Prague, 30.10.2015

Place and date



Ing. Daniel Jarchovský